



## Certified Capability List

This Capability List is based on a certification session performed by the *TALQ Certification Tool (v2.2.0)* on 2020-04-09 19:42:01.856 +0530.

The Capability List is a consolidated list of TALQ features which are implemented in a product.

The tool has successfully performed 28 tests.

## Product details

**Product Name** CIMCON Nearsy Gateway/Bridge

**Company** CIMCON Lighting, Inc.

**Type** GATEWAY

**Notes** Cimcon's NearSky TALQ Gateway/ Bridge unlocks the potential to integrate smart city data from disparate IOT sensors and "data silos". Data from multiple networks such as connected street lighting network and other IoT platforms enabled by a common technology, helps to drive efficient and optimized operational model throughout the city. The NearSky TALQ Gateway/ Bridge allows to protect investment in previously deployed solutions including aggregation & analytics for the street light network & diverse IoT sensors and unlock the elusive promised ROI of a truly integrated smart city.

**Generated on** 2020-04-09 19:42:01.856 +0530

**Supported profiles**

- LIGHTING

**Certification performed by app version:** 2.2.0

# Capability list

## Security

Enabled ✓

## Functions

### Basic

The Basic function describes the properties related to the physical asset to which the logical device is associated, such as identification (assetId) and location information.

### Attributes

#	Attribute	Description
✓	serial	Serial number of the device.
✓	hwVersion	Hardware revision of the device.
✓	swVersion	Software version installed on the device.
✓	installationDate	The installation date of Physical Device.
✓	currentTime	Current time of the device defined as local time with time zone designator.

### Events

#	Event type	Description
✓	deviceReset	The physical device containing the logical device was reset

### Communication

The Communication Function contains attributes related to the communication within the ODN, and between ODN devices and Gateways. Although communication within the ODN is outside the scope of the TALQ Smart City Protocol, this Function enables access to a minimum set of configuration and state information of the ODN communication interface in order to facilitate system management from the CMS.

### Attributes

#	Attribute	Description
✓	communicationType	Type of communication technology implemented by the ODN (e.g. power line, wireless).
✓	logicalAddress	Logical address for communication within the ODN scope (IP address, Short Address, ...).
✓	physicalAddress	Physical address of the device. For example, IEEE MAC address. This attribute can be used to map between logical and physical devices. The format is specific to the ODN implementation.
✓	parentAddress	TALQ Address of the parent device, e.g. gateway. It shall point to a specific communication function.

## Events

#	Event type	Description
✓	communicationFailure	This event is generated by the ODN when the communication function is not operating as expected

## Gateway

The Gateway function includes the necessary attributes to enable the communication between the CMS and the Gateway according to the TALQ Specification.

### Attributes

#	Attribute	Description
✓	cmsUri	Base URI for TALQ communication that allows the Gateway to access the CMS. Must be an absolute URI. Other URI's for accessing CMS can be relative to this base.
✓	cmsAddress	CMS UUID address
✓	gatewayUri	Base URI for TALQ communication that allows the CMS to access the Gateway. Must be an absolute URI. Other URI's for accessing Gateway can be relative to this base.
✓	gatewayAddress	Gateway UUID address
✓	retryPeriod	Time duration before the Gateway retransmits a message for which expected response has not been received.
✓	crlUrn	URI where the Gateway can obtain the Certification Revocation List (CRL).
✓	vendor	Vendor identification.

## Lamp Actuator

The Lamp Actuator function includes attributes related to lighting control and it represents the smallest unit for control purposes. In practice, however, a Lamp Actuator function can control combinations of several lamps and control gear but all in the same way, as if they are all one individual unit.

### Attributes

#	Attribute	Description
✓	defaultLightState	Sets the default light output for the lamp actuator. This shall be applicable if no other command is active. This attribute shall be set to 100% as default value.
✓	targetLightCommand	Latest command for the lamp actuator.
✓	feedbackLightCommand	This attribute reflects the command in effect and it might deviate from the actualLightState due to propagation time or due to internal ODN specific mechanisms to handle the priority of the requests.
✓	actualLightState	This attribute should reflect the physical state of the light source as much as possible, including factors such as CLO. It may be calculated or measured, depending on the specific ODN implementation, which is outside the scope of this specification.
✓	calendarID	TALQ Address of the calendar controlling this lamp actuator. If this attribute is empty, the behavior shall be determined by the ODN. If the attribute is invalid, the ODN shall trigger a generic invalid address event and the behavior shall be determined by the ODN.

### Events

#	Event type	Description
✓	lightStateChange	Light state has changed

## Lamp Monitor

The Lamp Monitor function enables monitoring of lamp parameters. A Lamp Monitor function should be associated with a specific lamp/control gear combination. Multiple lamp monitor functions may be implemented by a single device.

### Attributes

#	Attribute	Description
---	-----------	-------------

- ✓ **supplyVoltage** RMS supply volts when supplyType is AC, supply voltage (V) when supplyType is DC.
- ✓ **supplyCurrent** RMS supply current (A) when supplyType is AC, supply current (A) when supplyType is DC.

**Events**

#	Event type	Description
✓	lampFailure	The lamp is not operating as it is supposed to

**Services**

**Configuration Service**

The TALQ Configuration Service enables discovery and configuration of devices and services

**Options**

#	Option	Value	Description
✓	devicesPaginationSupported*		This ODN can support pagination of devices.

**Control Service**

The Control service describes the mechanisms to operate the actuator functions in order to enable schedule based and override control

**Options**

#	Option	Value	Description
✓	supportedTypes	<ul style="list-style-type: none"> <li>• AbsoluteActivePeriod</li> <li>• FixedControlEffect*</li> <li>• ccDate*</li> </ul>	Control Program and calendar options supported are defined by announcing support for the given modes
✓	maximumCalendars		Maximum number of calendars supported

✓ maxProgramsPerCalendar		Maximum number of control programs per calendar
✓ maxSwitchPointsPerProgram		Maximum number of switching points per control program
✓ dayOffset	<ul style="list-style-type: none"> <li>• 1</li> <li>• 2</li> </ul>	Offset of start of day

**Events**

#	Event Type	Description
✓	invalidCalendar	An invalid calendar has been provided by the CMS to the ODN
✓	invalidProgram	A control program has been provided by the CMS, which cannot be implemented by the ODN

**Data Collection Service**

The TALQ Data Collection Service is a provision to configure how ODN measurements, status information and events are logged, and when or under what conditions the logged data is transferred to the CMS

**Options**

#	Option	Value	Description
✓	supportedModes	<ul style="list-style-type: none"> <li>• VendorRecordingMode*</li> <li>• EventRecordingMode</li> <li>• ImmediateReportingMode</li> </ul>	Recording and Reporting modes supported

**Events**

#	Event Type	Description
✓	invalidLoggerConfig	The CMS has provided a data logger configuration that cannot be implemented by the ODN

**On Demand Data Request Service**

This service provides the mechanism to access attributes in the logical devices by requesting attribute values from the ODN

## Test Service

This service provides a mechanism to reduce the human intervention during the certification tests, enabling the certification tests to maximise automation

## Objects

### Event log data

#### Properties

#	Property	Description
✓	eventType	Identifier of event reported
✓	srcAddress	Address of Logical device or function within a logical device which is the source of the event or to which this event applies

### Command

#### Properties

#	Property	Description
✓	state	Light state to be applied to the lamp actuator
✓	cmsRefId	CMS reference, which can be used for data logging

\*: The Certification Test Tool is designed to provide a high level of confidence that complementary systems can communicate successfully. As both the protocol and the test tool evolve, all mandatory and other core tests are confirmed by comparison with real-life scenarios (plug-fest or similar). Some tests of optional and more peripheral features may not yet have been confirmed in this way; such features are identified with an asterisk (\*).

This Capability List is based on a certification session performed by the TALQ Certification Tool (v2.2.0) on 2020-04-09 19:42:01.856 +0530.

© TALQ Consortium

