



# Certified Capability List

This Capability List is based on a certification session performed by the *TALQ Certification Tool (v2.3.0-update.8) on 2021-06-07 17:43:17.587 +0200*.

The Capability List is a consolidated list of TALQ features which are implemented in a product.

The tool has successfully performed 28 tests.

## Product details

**Product Name** LuxSave Streetlight GW

**Company** LuxSave AS

**Type** GATEWAY

### Notes

**Generated on** 2021-06-07 17:43:17.587 +0200

**Supported profiles** • LIGHTING

**Certification performed by app version:** 2.3.0-update.8

## Capability list

### Security

Enabled ✓

# Functions

## Basic

The Basic function describes the properties related to the physical asset to which the logical device is associated, such as identification (assetId) and location information.

### Attributes

#	Attribute	Description
✓	swVersion	Software version installed on the device.
✓	location	Latitude, Longitude and Altitude. [DEPRECATED: This attribute has been deprecated and it will be removed in the next MAJOR release. Please use the new LocationSensorFunction.location instead.]
✓	currentTime	Current time of the device defined as local time with time zone designator. [DEPRECATED: This attribute has been deprecated and it will be removed in the next MAJOR release. Please use the new TimeFunction.currentTime instead.]

### Events

#	Event type	Description
✓	deviceReset	The physical device containing the logical device was reset

## Communication

The Communication Function contains attributes related to the communication within the ODN, and between ODN devices and Gateways. Although communication within the ODN is outside the scope of the TALQ Smart City Protocol, this Function enables access to a minimum set of configuration and state information of the ODN communication interface in order to facilitate system management from the CMS.

### Attributes

#	Attribute	Description
✓	physicalAddress	Physical address of the device. For example, IEEE MAC address. This attribute can be used to map between logical and physical devices. The format is specific to the ODN implementation.

### Events

#	Event type	Description
---	------------	-------------

- ✓ communicationFailure This event is generated by the ODN when the communication function is not operating as expected

## Gateway

The Gateway function includes the necessary attributes to enable the communication between the CMS and the Gateway according to the TALQ Specification.

### Attributes

#	Attribute	Description
✓	cmsUri	Base URI for TALQ communication that allows the Gateway to access the CMS. Must be an absolute URI. Other URI's for accessing CMS can be relative to this base.
✓	cmsAddress	CMS UUID address
✓	gatewayUri	Base URI for TALQ communication that allows the CMS to access the Gateway. Must be an absolute URI. Other URI's for accessing Gateway can be relative to this base.
✓	gatewayAddress	Gateway UUID address
✓	retryPeriod	Time duration before the Gateway retransmits a message for which expected response has not been received.
✓	crlUrn	URI where the Gateway can obtain the Certification Revocation List (CRL).
✓	vendor	Vendor identification.

## Lamp Actuator

The Lamp Actuator function includes attributes related to lighting control and it represents the smallest unit for control purposes. In practice, however, a Lamp Actuator function can control combinations of several lamps and control gear but all in the same way, as if they are all one individual unit.

### Attributes

#	Attribute	Description
✓	defaultLightState	Sets the default light output for the lamp actuator. This shall be applicable if no other command is active. This attribute shall be set to 100% as default value.
✓	targetLightCommand	Latest command for the lamp actuator.

✓ feedbackLightCommand	This attribute reflects the command in effect and it might deviate from the actualLightState due to propagation time or due to internal ODN specific mechanisms to handle the priority of the requests.
✓ actualLightState	This attribute should reflect the physical state of the light source as much as possible, including factors such as CLO. It may be calculated or measured, depending on the specific ODN implementation, which is outside the scope of this specification.
✓ calendarID	TALQ Address of the calendar controlling this lamp actuator. If this attribute is empty, the behavior shall be determined by the ODN. If the attribute is invalid, the ODN shall trigger a generic invalid address event and the behavior shall be determined by the ODN.

## Events

#	Event type	Description
✓	lightStateChange	Light state has changed

## Services

### Configuration Service

The TALQ Configuration Service enables discovery and configuration of devices and services

#### Options

#	Option	Value	Description

### Control Service

The Control service describes the mechanisms to operate the actuator functions in order to enable schedule based and override control

#### Options

#	Option	Value	Description

<input checked="" type="checkbox"/> supportedTypes	<ul style="list-style-type: none"> <li>AbsoluteActivePeriod</li> <li>AstroClockActivePeriod*</li> </ul>	Control Program and calendar options supported are defined by announcing support for the given modes
--	---	--

## Events

#	Event Type	Description
<input checked="" type="checkbox"/>	invalidCalendar	An invalid calendar has been provided by the CMS to the ODN
<input checked="" type="checkbox"/>	invalidProgram	A control program has been provided by the CMS, which cannot be implemented by the ODN

## Data Collection Service

The TALQ Data Collection Service is a provision to configure how ODN measurements, status information and events are logged, and when or under what conditions the logged data is transferred to the CMS

## Options

#	Option	Value	Description
<input checked="" type="checkbox"/>	supportedModes	<ul style="list-style-type: none"> <li>VendorRecordingMode*</li> <li>EventRecordingMode</li> <li>ImmediateReportingMode</li> </ul>	Recording and Reporting modes supported

## Events

#	Event Type	Description
<input checked="" type="checkbox"/>	invalidLoggerConfig	The CMS has provided a data logger configuration that cannot be implemented by the ODN

## On Demand Data Request Service

This service provides the mechanism to access attributes in the logical devices by requesting attribute values from the ODN

## Test Service

This service provides a mechanism to reduce the human intervention during the certification tests, enabling the certification tests to maximise automation

# Objects

## Event log data

### Properties

#	Property	Description
---	----------	-------------

- |   |            |   |
|---|------------|---|
| ✓ | eventType  | Identifier of event reported  |
| ✓ | srcAddress | Address of Logical device or function within a logical device which is the source of the event or to which this event applies |

## Command

### Properties

#	Property	Description
---	----------	-------------

- |   |          |   |
|---|----------|---|
| ✓ | state    | Light state to be applied to the lamp actuator    |
| ✓ | cmsRefId | CMS reference, which can be used for data logging |

\*: The Certification Test Tool is designed to provide a high level of confidence that complementary systems can communicate successfully. As both the protocol and the test tool evolve, all mandatory and other core tests are confirmed by comparison with real-life scenarios (plug-fest or similar). Some tests of optional and more peripheral features may not yet have been confirmed in this way; such features are identified with an asterisk (\*).

This Capability List is based on a certification session performed by the TALQ Certification Tool (v2.3.0-update.8) on 2021-06-07 17:43:17.587 +0200.

 and **TALQ** are trademarks owned by the TALQ Consortium.

 TALQ Consortium

