



Certified Capability List

This Capability List is based on a certification session performed by the *TALQ Certification Tool (v2.5.1-update.2)* on 2024-02-02 08:30:28.719 +0800.

The Capability List is a consolidated list of TALQ features which are implemented in a product.

The tool has successfully performed 26 tests.

Product details

Product Name StarRiver Pro Gateway

Company Shanghai Sansi Electronic Engineering Co., Ltd.

Type GATEWAY

Notes

Generated on 2024-02-02 08:30:28.719 +0800

Supported profiles • Lighting

API version certified: 2.5.1

Certification performed by app version: 2.5.1-update.2

Capability list

Security

Enabled ✓

Functions

Basic

The Basic function describes the properties related to the physical asset to which the logical device is associated, such as identification (assetId) and location information.

Attributes

| # | Attribute | Description |
|---|-------------|---|
| ✓ | swVersion | Software version installed on the device. |
| ✓ | currentTime | Current time of the device defined as local time with time zone designator. [DEPRECATED: This attribute has been deprecated and it will be removed in the next MAJOR release. Please use the new TimeFunction.currentTime instead.] |

Events

| # | Event type | Description |
|---|-------------|---|
| ✓ | deviceReset | The physical device containing the logical device was reset |

Gateway

The Gateway function includes the necessary attributes to enable the communication between the CMS and the Gateway according to the TALQ Specification.

Attributes

| # | Attribute | Description |
|---|----------------|---|
| ✓ | cmsUri | Base URI for TALQ communication that allows the Gateway to access the CMS. Must be an absolute URI. Other URI's for accessing CMS can be relative to this base. |
| ✓ | cmsAddress | CMS UUID address |
| ✓ | gatewayUri | Base URI for TALQ communication that allows the CMS to access the Gateway. Must be an absolute URI. Other URI's for accessing Gateway can be relative to this base. |
| ✓ | gatewayAddress | Gateway UUID address |

| | |
|---------------|--|
| ✓ retryPeriod | Time duration before the Gateway retransmits a message for which expected response has not been received. [DEPRECATED: This attribute has been deprecated and it will be removed in the next MAJOR release. Please use the new GatewayFunction.gatewayRetryPeriod instead.] |
| ✓ crlUrn | URI where the Gateway can obtain the Certification Revocation List (CRL). |
| ✓ vendor | Vendor identification. |

Lamp Actuator

The Lamp Actuator function includes attributes related to lighting control and it represents the smallest unit for control purposes. In practice, however, a Lamp Actuator function can control combinations of several lamps and control gear but all in the same way, as if they are all one individual unit.

Attributes

| # | Attribute | Description |
|---|----------------------|---|
| ✓ | defaultLightState | Sets the default light output for the lamp actuator. This shall be applicable if no other command is active. This attribute shall be set to 100% as default value. |
| ✓ | targetLightCommand | Latest command for the lamp actuator. |
| ✓ | feedbackLightCommand | This attribute reflects the command in effect and it might deviate from the actualLightState due to propagation time or due to internal ODN specific mechanisms to handle the priority of the requests. |
| ✓ | actualLightState | This attribute should reflect the physical state of the light source as much as possible, including factors such as CLO. It may be calculated or measured, depending on the specific ODN implementation, which is outside the scope of this specification. |
| ✓ | calendarID | TALQ Address of the calendar controlling this lamp actuator. If this attribute is empty, the behavior shall be determined by the ODN. If the attribute is invalid, the ODN shall trigger a generic invalid address event and the behavior shall be determined by the ODN. |

Events

| # | Event type | Description |
|---|------------------|-------------------------|
| ✓ | lightStateChange | Light state has changed |

Lamp Monitor

The Lamp Monitor function enables monitoring of lamp parameters. A Lamp Monitor function should be associated with a specific lamp/control gear combination. Multiple lamp monitor functions may be implemented by a single device.

Attributes

| # | Attribute | Description |
|---|-------------|---------------|
| ✓ | activePower | Active power. |

Events

| # | Event type | Description |
|---|-------------|--|
| ✓ | lampFailure | The lamp is not operating as it is supposed to (e.g. the lamp is broken). This event shall be used to detect a situation where the lamp (or LED module(s)) should be lit, but produce no light. This could be detected by the current flowing or power consumed. |

Services

Configuration Service

The TALQ Configuration Service enables discovery and configuration of devices and services

Options

| # | Option | Value | Description |
|---|--------|-------|-------------|
|---|--------|-------|-------------|

Control Service

The Control service describes the mechanisms to operate the actuator functions in order to enable schedule based and override control

Options

| # | Option | Value | Description |
|---|--------|-------|-------------|
|---|--------|-------|-------------|

Events

| # | Event Type | Description |
|---|------------|-------------|
|---|------------|-------------|

- ✓ **invalidCalendar** An invalid calendar has been provided by the CMS to the ODN
- ✓ **invalidProgram** A control program has been provided by the CMS, which cannot be implemented by the ODN

Data Collection Service

The TALQ Data Collection Service is a provision to configure how ODN measurements, status information and events are logged, and when or under what conditions the logged data is transferred to the CMS

Options

| # | Option | Value | Description |
|---|----------------|---|---|
| ✓ | supportedModes | <ul style="list-style-type: none"> • VendorRecordingMode • EventRecordingMode • ImmediateReportingMode | Recording and Reporting modes supported |

Events

| # | Event Type | Description |
|---|---------------------|--|
| ✓ | invalidLoggerConfig | The CMS has provided a data logger configuration that cannot be implemented by the ODN |

On Demand Data Request Service

This service provides the mechanism to access attributes in the logical devices by requesting attribute values from the ODN

Objects

Event log data

Event log data contains a single event, with eventType and value, in each single log entry. It also includes information about whether the log denotes the start or end of the event. Furthermore additional information can be added with the info attribute.

Properties

| # | Property | Description |
|---|-----------|------------------------------|
| ✓ | eventType | Identifier of event reported |

- ✓ **srcAddress** Address of Logical device or function within a logical device which is the source of the event or to which this event applies

Command


A command defines a type of control action that can be applied to a function. Commands can be generated by a manual override action or by a control program.

Properties

| # | Property | Description |
|---|----------|---|
| ✓ | state | Light state to be applied to the lamp actuator |
| ✓ | cmsRefId | CMS reference, which can be used for data logging. The cmsRefId in a Command is a free text to be used by the CMS for any purpose, e.g: to differentiate contexts. It is a token that allows the CMS to match client requests to the original notification. |

: The Certification Test Tool is designed to provide a high level of confidence that complementary systems can communicate successfully. As both the protocol and the test tool evolve, all mandatory and other core tests are confirmed by comparison with real-life scenarios (plug-fest or similar). Some tests of optional and more peripheral features may not yet have been confirmed in this way; such features are identified with an asterisk ().

This Capability List is based on a certification session performed by the TALQ Certification Tool (v2.5.1-update.2) on 2024-02-02 08:30:28.719 +0800.

 and **TALQ** are trademarks owned by the TALQ Consortium.

© TALQ Consortium

